



TOWN OF UNION BRIDGE

Request for Proposal
Addendum No. 1

Town of Union Bridge
Quaker Hill Road
New Water Service Lines
September 2024

SUBMIT BID TO:

Town of Union Bridge
104 W. Locust Street
Union Bridge, MD 21791

ADDENDUM ISSUED: 09/13/2024
PROPOSALS DUE: 9/20/2024

II. STATEMENT OF WORK

A. General Description: Replace Paragraph 1 with the following:

The Town of Union Bridge, Maryland is soliciting proposals for the installation of new lead-free 1-inch diameter copper water laterals. The approximate locations of the existing 6- and 8-inch diameter water mains and the building service line entry points are depicted in the attached Site Plan - Aerial Map. The approximate tapping locations are depicted on the attached Existing Water Main Site Plan. The selected contractor will be responsible for furnishing all labor, material, equipment, services, design, permits, construction, and obtaining all requisite approvals and signatures.

B. Scope of Work: Replace Paragraph 2 with the following:

Contractor shall install two new water laterals by tapping into the existing 8-inch ductile iron cement lined (DICL) Class 52 water main shown on the attached Site Plan - Aerial Map and Existing Water Main Site Plan. The water laterals shall generally consist of pipe, corporation stop, curb stop and valve box, and flow meter vault. The water laterals shall be connected to the existing water main by use of service tapping saddles in accordance with Carroll County Department of Public Works, Bureau of Utilities Design Manual Water and Sewer.

Project requirements are as follows: Replace Paragraph 2 as follows:

1. Contractor shall determine the locations of the water main at both approximated tapping locations by soft dig or other technique approved by the Town prior to conducting water main tapping work.

Replace Paragraphs 13 and 14 as follows:

13. If saw cutting of existing roadway is necessary (Contingent Bid Item), Contractor shall place temporary asphalt and maintain patch until permanent pavement is placed.
14. If saw cutting of existing roadway is necessary (Contingent Bid Item), Contractor shall replace temporary asphalt with permanent pavement in accordance with Carroll County Department of Public Works, Bureau of Utilities Design Manual Water and Sewer, Standard Detail G-2, Pavement Restoration (attached to this RFP).

Request for Proposal

Add new Paragraphs as follows:

- 18. Contractor shall remove existing flow meter vault located between residential homes at 420 and 422 Quaker Hill Road.
- 19. Contractor shall be made aware of an existing Town of Union Bridge water main easement that is five feet wide and runs parallel to Quaker Hill Road. Please see the Existing Water Main Site Plan. Contractor shall set the new Flow Meter Vaults approximately five feet from the edge of pavement.

III. PROPOSAL REQUIREMENTS

A. Required elements: Replace Paragraph 4 with the following:

- 4. Bid price must be lump sum and include all services required to fulfill the Scope of Work. Partial or incomplete bids will not be accepted.

PROPOSAL PRICE: Replace both tables with the following:

BID PROPOSAL PRICE

ITEM	ADDRESS	UNIT	APPROXIMATE QUANTITY	UNIT PRICE	TOTAL PRICE
8" Water Main Tap	420 & 422 Quaker Hill Rd	EA	2		
Water Meter Vault	420 & 422 Quaker Hill Rd	EA	2		
1" Copper Service Line (open trench)	420 Quaker Hill Rd	LF	73		
1" Copper Service Line (open trench)	422 Quaker Hill Rd	LF	115		
Contingent Item	Pavement Cutting, removal and excavation	SF	16		
Contingent Item	Pavement Restoration	SF	16		

I do hereby certify that the above proposal is submitted by the undersigned and not as agent for anyone else, that no other parties have an interest as principal or agent, and that the undersigned, his/her employees, agents and servants did not directly or indirectly discourage anyone from bidding or submitting any proposal in this matter.

Request for Proposal

Submitted this _____ day of _____ 2024.

PLEASE CIRCLE: INDIVIDUAL PARTNERSHIP CORPORATION

NAME: _____

Street and/or P.O. Box _____

City _____ State _____ Zip Code _____

Fed ID or SSN _____

Business Phone Number _____ Business Fax Number _____ E-Mail Address _____

(SEAL) _____

Signature

Date

Print Name

WITNESS: _____
Signature

Print Name